



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders Ref: 8/3/55-2021 Tel: (022) 022 913 6038 E-mail: saundersi@bergmun.org.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM: 1

TENDER NR 8/3/55 – 2021 (MN258 – 2021) UPGRADING OF CHALETS AT DWARSKERSBOS

ADDENDUM NO. 1:

Pursuant to the compulsory clarification meeting held on Tuesday, 23 November 2021, bidders must kindly note the following:

1. Vibacrete Replacement

Northern section; 41 panels, 42 poles/ uprights of 2,4m to make a wall height of 1,8m (put back the barbed wire topping-off the fence)

Southern section; 19 panels, 20 poles/ uprights of 2,4m to make a wall height of 1,8m

2. Install aluminium doors and frames, as well as safety gates

colour; natural aluminium

all doors and safety gates galvanized

5 year guarantee must be submitted with the installation on the aluminium works

3. Tiling on Stoep (X12)

Tile spec; Lekwa Slate Brown floor tile, 1st grade, 400 X 400mm

Dimensions to be covered; 156m²

4. Construction of Ramps

Ramps will be a maximum of 4,5m x 1,5m and the final design must be done by an engineer to be appointed by the successful bidder, and covered by the provisional sum

5. Signage on Windows

Vinyl or similar lettering/wording must be used, which is washable and durable, stuck on the outside of the windows



BERGRIVIER MUNICIPALITY

MUNICIPAL MANAGER

DATE:

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of
(Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:
..... Fax no.:
.....
.....

Signature of bidder: Date:

This document must be completed by the bidder (above) and submitted with his offer.