



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders Ref: 8/2/43-2022 Tel: (022) 022 913 6038 E-mail: saundersi@bergmun.org.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM: 1

TENDER NR 8/2/43 – 2022 (MN 159 – 2022) SUPPLY & INSTALLATION OF HEAVY DUTY STEEL GARAGE DOORS AT THE TRAFFIC TEST PIT IN VELDDIRF

Pursuant to the compulsory clarification meeting held on Thursday, 18 August 2022, bidders must kindly note the following:

1. ADDITIONS TO TECHNICAL SPECIFICATIONS

Doors dimensions to match existing, roughly:

- Eastern side door opening 1880 x 2 x 4270
- Western side door opening 1880 x 2 x 4270

- Material for doors, Colourbond AZ 200, to match existing profile, coated with a grey primer, and finished off with two coats of red on both sides)
- Sliding track flat bar 100 mm x 6mm x 8m and lain in a concrete footing with stop ends for doors, galvanized, with 80mm diameter wheels with at least a 6mm -10mm groove bearing
- Door frame angled iron of at least 50mm x 40mm x 6mm
- All steel components to be galvanized, and a galvanizing certificate must be supplied on completion of the works
- Upper track with pelmet/canopy to match existing (± 8 m)
- On the eastern side make a door opening of ± 800 mm x 2.1m, opening to the right and out, with a catch and flushed lock with 4 keys, which must both be aesthetically pleasing and functional, according to the design of the engineer
- Provide 2 disk locks
- Add sliding barrel bolts x 2 + catches to match existing

2. REVISED CLOSING DATE

- Please note that the closing date has been revised, and bids must now be submitted on **FRIDAY, 2 SEPTEMBER 2022**



BERGRIVIER MUNICIPALITY

3. REQUIREMENTS FOR ENGINEERING DESIGNS, DRAWINGS, SPECIFICATIONS AND CERTIFICATION

Bidders must secure pricing from the engineers and make provision for at least;

- 2 site visits
- engineering designs, drawings and specifications
- these drawings must, after appointment be submitted to the municipality for approval, before manufacturing and construction can occur
- On completion of this assignment, the engineer must issue a certificate that the doors were installed according to the designs and specifications

FINAL TENDER AMOUNT		
1	SUPPLY & INSTALLATION OF TWO STEEL ACCESS DOORS	PRICE
1.1	Western Side Door Complete (including tracks, pelmet & galvanizing)	R
1.2	Eastern Side Door Complete (including tracks, pelmet & galvanizing)	R
2	Engineering Designs, Drawings & Inspections	R
3	Provisional Sum	R20 000,00
	Total (VAT Inclusive)	R

Bidders must use the pricing schedule herein and ignore the previous one. Kindly note that the municipality reserves the right to replace, amend, withdraw or supplement the specifications, and to award the job either in part or as a whole.

MUNICIPAL MANAGER

DATE:

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of (Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:

..... Fax no.:

.....

Signature of bidder: Date:

This document must be completed by the bidder (above) and submitted with his offer.