



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders Ref: 8/2/56-2022 Tel: (022) 022 913 6038 E-mail: saundersi@bergmun.org.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM: 2

FQ NR 8/2/56 – 2022 (MN 210 – 2022) SUPPLY & INSTALLATION OF AIR-CONDITIONING UNITS FOR BERGRIVIER MUNICIPAL TRAFFIC OFFICES IN VELDDRIF

Pursuant to the compulsory clarification meeting held on Thursday, 13 October 2022, bidders must kindly note the following:

- The contractors present have, for purposes of uniformity and fairness, to only price on Samsung-aircons, 12 000 BTU
- Bluchem anti-corrosion, clear coating, specifically designed for HVAC-equipment must be applied to, about 50 microns over the metal substrates
- Installation of all units must be done within two (2) weeks after receiving an official order
- The outside unit for the registration office must be fitted above the steel (safe) door, and the drain-pipe to discharge at the western-side entrance

Kindly use the pricing schedule below and ignore the one in the original tender document:

DESCRIPTION	REGISTRATION OFFICE	DESCRIPTION	SUP. OFFICE
SPLIT UNIT, INVERTER	R	SPLIT UNIT, INVERTER	R
AIRCON PIPEKIT & COVER (10M PER UNIT)	R	AIRCON PIPEKIT & COVER (10M PER UNIT)	R
ISOLATOR & WP BOX PVC	R	ISOLATOR & WP BOX PVC	R
20 AMP BREAKER	R	20 AMP BREAKER	R
T&E WIRE 10M	R	T&E WIRE 62M	R
PVC CABLE SCORE 10M	R	PVC CABLE SCORE 62M	R
AIRCON BRACKETS (SET, SLOW CURVE)	R	AIRCON BRACKETS (SET, SLOW CURVE)	R
PVC CONDUIT PIPE & COACH SCREWS & SADDLES (10M)	R	PVC CONDUIT PIPE & COACH SCREWS & SADDLES (62M)	R
SUPPLY & FIT STEEL CAGES	R	SUPPLY & FIT STEEL CAGES	R
COC FOR INSTALLATION	R	COC FOR INSTALLATION	R
COC FOR ELECTRICAL WORKS	R	COC FOR ELECTRICAL WORKS	R
PROVISIONAL SUM	R5 000,00	PROVISIONAL SUM	R5 000,00
VAT (15%)	R	VAT (15%)	R
TOTAL	R	TOTAL	R



BERGRIVIER MUNICIPALITY

Kindly note that the provisional sum will make allowance for shop drawings and other unforeseen expenses, where these arise. Such expenses cannot be incurred without the prior written approval of the municipality. Where shop drawings and designs are required, these must be submitted to the municipality for approval, at least 3 days before it can be used for construction/installation purposes.

[Handwritten Signature]
MUNICIPAL MANAGER

DATE: *17/10/2022*

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of (Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:
..... Fax no.:
.....

Signature of bidder: Date:

This document must be completed by the bidder (above) and submitted with his offer.