



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders Ref: 8/3/19-2021 Tel: (022) 022 913 6038 E-mail: saundersi@bergmun.org.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM:

TENDER NR 8/3/19 – 2021 (MN80 – 2021): SUPPLY AND DELIVERY OF WATER TREATMENT CHEMICALS

ADDENDUM NO. 1:

Changes to the document under the specifications:

(*) Special Conditions for SUDFLOC 3870

1. It is expected of the tenderer to provide the following value added services:
 - Total dosing system for Piketberg WTW
 - 1 + 1 Dosing pump system which must be serviced two(2) x per year
 - PLC control system with pre-define algorithms – Must be able to communicate with SCADA system for data exchange if required
 - Pumps must be controlled via 4-20 mA signal
 - Easy to setup, easy to use
 - Must have remote monitoring and diagnostics capabilities

2. Remote monitoring of the following parameters:
 - Raw water: Turbidity
 - Final water – pH, Turbidity and Free Chlorine

The remote monitoring of the pH and Turbidity on the final water will no longer be required by the successful tenderer.



BERGRIVIER MUNICIPALITY

MUNICIPAL MANAGER

DATE:

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of (Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:
..... Fax no.:
.....

Signature of bidder: Date:

This document must be completed by the bidder (above) and submitted with his offer.